



District Level Water Analysis Laboratory

UP Jal Nigam (Rural), Bulandshahr

TEST REPORT

UTR NO:	: T 9249	Issue Date	09/09/2025
Sample receipt Date:	: 08/09/2025	Expired Date	08/03/2026
Customer/Party Name	: GYAN JYOTI PUBLIC SCHOOL		
Address	: VILL. CHHINORA, KHANPUR DISTT. BULANDSHAHR .203001		
Contact No.	: 7055988380		
Date of Sampling	: 08/09/2025	Sample Code:	
Sample Description	: 08/09/2025	Quantity of Sample	1000ML
Quantity	: 1	Water Source	SUMER SIBLE WATER
Packing details	:	Sampling Method	As per IS 17614:Part-
Analysis Start	: 08/09/2025	Analysis Completion Date	09/09/2025
Temperature	: 31.1°C	Humidity	53 %

Water Sample Provided By N. K. Tyagi

Availability of Equipments:		Availability of reference standards:		Adequacy of sample quantity	01
Availability of Test method:	IS 3025	Availability of Trained person:		Duration of testing/Time of Report release	10:4 am

TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.631	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	3.320	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	550.30	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	150	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	510	(Mg/L)
6	Total Hardness	IS 3025 (Part 21):2019	200	600	480	(Mg/L)
7	Colour	APHA 23 rd Edistion	5	15	12	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitati
9	Odour	IS 3025 (Part): 2018	Agreeable	Agreeable	Agreeable	Agreeab
10	Calcium as Ca	-	75	200	146	(Mg/L)
11	Magnesium as	-	30	100	75.15	(Mg/L)

Remark

"The Information regarding sample collected, submitted and Customer basic details provided by the customer itself."

Reviewed By

End of Report




PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. T 92 49

Dated: 10/9/25

It is certified that an inspection team headed by Dr. Ranjit Kumar Singh
 (Name of Officers with designation) from CMO office Bulandshahr, Health Family
 (Name of Department/ Office) inspected the Gyan Jyoti Public School with
Khaspur Distt Bulandshahr.
 (Name & Address of the school) on 10/9/25 (date of inspection) and found that the
Gyan Jyoti Public School Khaspur (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 9/9/26Signature with Seal: Name: Dr. Ranjit Kumar SinghDesignation: DCOName & Address of the Office / Department: CMO office Bulandshahr

To

Gyan Jyoti Public School
With Chinnoro, Mayapatti
Khaspur Distt Bulandshahr (U.P.)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.